

DECLARATION OF CONFORMITY

According to Directive 2014/68/UE for a pressure equipment

The manufacturer: ZETKAMA Sp. z o.o. ul. 3 Maja 12, 57-410 Ścinawka Średnia, www.zetkama.com.pl

This declaration of conformity is issued under the sole responsibility of the manufacturer.

We hereby declare that stop valves listed below correspond to the Pressure Equipment Directive 2014/68/UE

Figure No. Connecting ends Shape	Material of Body	Nominal Diameter DN(mm)	Nominal Pressure PN(MPa)	Range of Working Temperature (°C)
215 Flanged ends Straight Form	Grey cast iron EN-GJL250	32 ÷ 300	1,6	-10 ÷ 300
	Nodular cast iron EN-GJS400-18-LT	32 ÷ 200	1,6	-10 ÷ 350
			2,5	-10 ÷ 350
	Cast steel GP240GH	32 ÷ 200	4,0	-20 ÷ 400
216 Flanged ends Angle Form	Grey cast iron EN-GJL250	32 ÷ 300	1,6	-10 ÷ 300
	Nodular cast iron EN-GJS400-18-LT	32 ÷ 200	1,6	-10 ÷ 350
2,5				
217 Welded ends Straight Form	Cast steel GP240GH	32 ÷ 200	4,0	-20 ÷ 450
	Stainless steel GX5CrNiMo19-11-2	32 ÷ 200	4,0	-60 ÷ 400
201 Screwed ends Straight Form	Grey cast iron EN GJL250	32 ÷ 50	1,6	-10 ÷ 200

Applied conformity assessment procedure: module H

The following harmonised standards have been applied: 1. EN-19; 2. EN-1515-4, 3; EN-1563, 4; EN-1092-1, 5; EN-10213, 6; EN-12266-1, 7; EN-12516-2, 8; EN-12516-3, 9; EN-12516-4, 10; EN-13709, 11; EN-13789.

The other standards have been applied: 1. EN-558; 2. EN-1561; 3. EN-1092-2; 4. EN-10088-3; EN-12266-2.

Engaged Notified Body: Bureau Veritas S.A., Newtime-52 Boulevard du Parc – Ile de la Jatte
92200 Neuilly sur Seine, No. 0062


Surveillance of Quality Systems – Examination, inspections and tests during manufacturing

CE– Certificate of conformity No. CE-0062-PED–H-ZKM 001-16-POL

Declaration of conformity No. 1/01/2018

Managing Director

Andrzej Mrozek



Ścinawka Średnia 3.01.2018